



(2003)国认监认字(043)号



(2003)量认(国)字(L0425)号



NO.L0698

NFTC

检 验 报 告

No: 200510575

受检单位名称: 佛山市南海区里水勇盈木业有限公司

产品型号名称: 菱镁不燃板 板厚6mm

检 验 类 别 : 型式检验 (安全性能)


国家防火建筑材料质量监督检验中心

国家防火建筑材料质量监督检验中心

检验报告

№: 200510575

共 3 页 第 1 页

产品名称	菱镁不燃板	型号规格	板厚6mm
受检单位	佛山市南海区里水勇盈木业有限公司	商 标	Y 勇盈
生产单位	佛山市南海区里水勇盈木业有限公司	检验类型	型式检验 (安全性能)
送检单位	佛山市南海区里水勇盈木业有限公司	抽样基数	3000m ²
抽样单位	国家防火建筑材料质量监督检验中心	生产日期	2005.07.21
抽样地点	公司仓库	抽样日期	2005.08.08
样品数量	450mm×450mm×6mm, 4块	到样日期	2005.08.17
样品编号	200511478	检验日期	2005.08.25
检验项目	不燃性 (A级)		
检验依据	GB 8624-1997 《建筑材料燃烧性能分级方法》		
检 验 结 论	<p style="text-align: center;">经检验, 该材料各项指标均符合不燃材料的规定要求。按GB 8624-1997判定, 该材料燃烧性能达到GB 8624 A级。 (以下空白)</p> <div style="text-align: right; margin-top: 20px;">  <p>签发日期: 2005年8月26日</p> </div>		
备注			

批准:

李凤

审核:

李欣

编制:

李绪斌

国家防火建筑材料质量监督检验中心 检验专用章

国家防火建筑材料质量监督检验中心

检验结果汇总表

生产单位：佛山市南海区里水勇盈木业有限公司

No: 200510575

产品型号：板厚6mm

共 3 页 第 2 页

序号	检验项目	检验方法	技术指标	检验结果	结论
1	炉内温升, °C	GB/T 5464-1999	≤50	2	合格
2	持续燃烧时间, s	GB/T 5464-1999	≤20	0	合格
3	质量损失率, %	GB/T 5464-1999	≤50.0	36.6	合格
	以	下	空	白	
备注	质量损失率检验结果展伸不确定度 $U_{95}=0.2\%$				



国家防火建筑材料质量监督检验中心
检 验 报 告

No: 200510575

共 3 页 第 3 页

生产单位	佛山市南海区里水勇盈木业有限公司		
通信地址	佛山市里水沙步工业区横3路7号		
法人代表	梁志聪	邮政编码	528244
联系电话	13703071778	传 真	0757-85784305

产品说明:

该材料主要由氧化镁、氯化镁、滑石粉、珍珠岩、木屑等组成。(以上信息由受检单位提供)





(2003)国认监认字(043)号



(2003)量认(国)字(L0425)号



NO.L0698

NFTC

检 验 报 告

TEST REPORT

No: 200510575

Tested Company: Fushan City Nanhai District Lishui Yongying Wood Industry Co., Ltd.

Name: Magnesia incombustible board


Testing Type: Sampling Test (Safty Performance)




国家防火建筑材料质量监督检验中心

NATIONAL CENTER FOR QUALITY SUPERVISION AND TESTING
OF FIRE BUILDING MATERIALS

**National Center for Quality Supervision and Testing of
Fire Building Materials
Test Report**

No: 200510575
1st of 3

Name	Magnesia incombustible board	Specifications	thickness: 6mm
Tested Company	Fushan City Nanhai District Lishui Yongying Wood Industry Co., Ltd.	Trade Mark	Y Yongying
Manufacturer	Fushan City Nanhai District Lishui Yongying Wood Industry Co., Ltd.	Testing Type	Sampling Test (Safty Performance)
Submitted by	Fushan City Nanhai District Lishui Yongying Wood Industry Co., Ltd.	Sampled Base	3000m ²
Sampled by	National Center for Quality Supervision and Testing of Fire Building Materials	Manufactured Date	Jul. 21 , 2005
Sampling Site	Warehouse of the company	Sampling Date	Aug. 08, 2005
Specimen Number	450mm ×450mm×6mm, 4 pcs	Specimen's Arrival Date	Aug. 17, 2005
Serial number	200511478	Testing Date	Aug. 25, 2005
Testing Item	Non-Combustibility (Class A)		
Testing according to	GB 8624-1997 <i>Classification on Burning Behaviour for Building Materials</i>		
Testing Conclusion	<p>As the result of test, all test indices of this material meet the requirements of non-combustible material. Judged according to GB 8624-1997, the fire performance rates at class A of GB 8624. (The following is blank.)</p> <div style="text-align: right;">  <p>Testing Seal 检测业务 Signing Date: Aug. 26, 2005</p> </div>		
Remark			

Approved by:  Verified by:  Drawn by: 

防火建筑材料质量监督检验中心

**National Center for Quality Supervision and Testing of
Fire Building Materials
Test Report**

No: 200510575

3rd of 3

Manufacturer	Fushan City Nanhai District Lishui Yongying Wood Industry Co., Ltd.		
Address	No.7 Hengsan Road Lishui Shabu Industry Zone Fushan City		
Legal Representative	Liang Zhicong	Post Code	528244
Tel.	13703071778	Fax	0757-85784305

Specimen description:

The specimen is composed of MgO, MgCl₂, talcum powder, perlite, wood chips etc.
(Information above is supplied by applicant.)

GB/T 5464 Pictures of the test:

